



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号
Certificate No. CE21.0162

| | |
|-----------------------------|---|
| 产品名称 Name of Product | 一体式门磁开关 |
| 型号及规格 Type of Product | JBF62D-33M |
| 防爆标志 Marking | Ex mb II C T6 Gb; Ex mbD 21 IP65 T80°C |
| 技术文件 Technical Documents | Q/JBF 021-2021 |
| 图号 Drawing No. | MCH04927 |
| 备注 Note (s) | 1. 额定电压: DC24V。 2. 环境温度: $-40^{\circ}\text{C} \leq T_a \leq +75^{\circ}\text{C}$ 。 |

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010 GB 3836.9-2014 GB 12476.1-2013 GB 12476.6-2010

发给: 青鸟消防股份有限公司

本证失效日期: 2026-10-15

Date of Expire:

发证日期: 2021-10-15

Date of Issue:

中心印章
Center seal



中心主任
Director

国家防爆产品质量检验检测中心 (天津)
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Product Quality Inspection and Testing Center (Tianjin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

<http://www.pcec.com.cn>