



# 防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号  
Certificate No. CE24. 2911

产品名称 Name of Product	工业及商业用途点型可燃气体探测器
型号及规格 Type of Product	GT-JBF5101G-Ex
防爆标志 Marking	Ex db II C T6 Gb
技术文件 Technical Documents	Q/JBF019-2024
图 号 Drawing No.	GT-JBF5101G-Ex-J00
备 注 Note (s)	本证书备注内容详见附录。

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB/T3836.1-2021

GB/T3836.2-2021

发 给: 青鸟消防股份有限公司

Issued to:

本证失效日期: 2029-08-06

Date of Expire:

发证日期: 2024-08-06

Date of Issue:

印章  
Seal



主任  
Director

韩承强

中海油天津化工研究设计院有限公司  
(国家防爆产品质量检验检测中心(天津))  
(石油和化学工业电气产品防爆质量监督检验中心)  
National Explosion-proof Product Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Post code: 300131

<http://www.pcec.com.cn>

电话/传真: 022-26651066 /26689116

Tel/ Fax: 022-26651066/26689116



# 防爆合格证附录

ANNEX OF CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号  
Certificate No. CE24. 2911

1. 关联检验报告: J2412911。
  2. 额定电压: DC24V。
  3. 额定功率:  $\leq 1W$ 。
  4. 环境温度:  $-40^{\circ}C \leq T_a \leq +70^{\circ}C$ 。
  5. 外壳防护等级: IP67。
  6. 生产企业: 北京惟泰安全设备有限公司第一分公司。
- 以下空白。

中海油天津化工研究院设计院有限公司  
(国家防爆产品质量检验检测中心(天津))  
(石油和化学工业电气产品防爆质量监督检验中心)  
National Explosion-proof Products Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Post code: 300131

<http://www.pcec.com.cn>

电话/传真: 022-26651066 /26689116

Tel/ Fax: 022-26651066/26689116