



防 爆 合 格 证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号
Certificate No. CE25. 0091

产 品 名 称 Name of Product	点型光电感烟火灾探测器
型号及规格 Type of Product	JTY-GD-JBF5101C-Ex
防 爆 标 志 Marking	Ex ib IIC T6 Gb
技 术 文 件 Technical Documents	Q / JBF 028-2022
图 号 Drawing No.	ASB-JBF5101C-Ex
备 注 Note (s)	本证书备注内容详见附件。

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB/T3836.1-2021

GB/T3836.4-2021

发 给: 青鸟消防股份有限公司
Issued to:

本证失效日期: 2030-01-07

Date of Expire:

发 证 日 期: 2025-03-10

Date of Issue:

印章
Seal



主任
Director

薛勇强

中 海 油 天 津 化 工 研 究 设 计 院 有 限 公 司
(国 家 防 爆 产 品 质 量 检 验 检 测 中 心 (天 津))
(石 油 和 化 学 工 业 电 气 产 品 防 爆 质 量 监 督 检 验 中 心)
National Explosion-proof Product Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Post code: 300131

<http://www.pcec.com.cn>

电话/传真: 022-26651066 /26689116

Tel/ Fax: 022-26651066/26689116



防 爆 合 格 证 附 录

ANNEX OF CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号 CE25.0091
Certificate No.

1. 额定电压: DC24V。
 2. 本安参数: U_i : 28V、 I_i : 93mA、 P_i : 1W、 C_i : 200pF、 L_i : 0mH。
 3. 产品使用环境温度: $-20^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$ 。
 4. 外壳防护等级: IP54。
 5. 此产品必须与安装在安全区的关联装置连接, 关联装置参数见使用说明书。
 6. 关联检验报告: J2510091 b。
- 以下空白。

中海油天津化工研究设计院有限公司
(国家防爆产品质量检验检测中心(天津))
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Products Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Post code: 300131

<http://www.pcec.com.cn>

电话/传真: 022-26651066 / 26689116

Tel/ Fax: 022-26651066/26689116